

Domestic Water System General Plan: Overview

INDIAN WELLS VALLEY WATER DISTRICT

BOARD OF DIRECTORS MEETING

DECEMBER 9, 2020



BACKGROUND

- ▶ Previous Water System General Plans: 1977, 1985 (Addendum), 1990, 1997
- ▶ 1996 estimated service area population was 35,600. Current (2019) estimated service area population is 35,800
- ▶ 1996 yearly production was 8,500 AF. Current (2019) yearly production is 6,116 AF.
- ▶ 1996 unit production was 210 gpcd. Current (2019) unit production is 150 gpcd.
- ▶ 1996 average occupancy was 3.36 persons/connection. Current (2019) average occupancy is 2.84 persons per connection.




WATER DEMANDS

- ▶ Population Projections
- ▶ Water Use Per Capita
- ▶ Service Area Profile
- ▶ Production Requirements to Meet Projected Demands
- ▶ Demand Distribution
- ▶ Average and Maximum Day Demands
- ▶ Storage Components
- ▶ Fire Flow Requirements by Pressure Zone
- ▶ Production Requirements by Pressure Zone


POPULATION

- ▶ Population projections for Kern County portion of service area is based on KernCOG estimates for 2020, 2035, and 2042. Projected growth rate from 2020 forward is slightly less than 1%.
- ▶ Population estimates for San Bernardino County portion of service area is based on number of connections multiplied by persons/household from 2014-2018 census data (2.57 to 2.61 persons/household). Projected number of connections is assumed to be proportional to population increase in Kern County portion of service area.

GENERAL PLAN COMPARISON PROJECTED POPULATION



Per-Capita Production, GPD



**INDIAN WELLS VALLEY WATER DISTRICT
DOMESTIC WATER SYSTEM
2018 SERVICE AREA PROFILE**

| CUSTOMER TYPE | SERVICES | % OF TOTAL SERVICES |
|----------------------|-----------------|----------------------------|
| Single Family | 11,697 | 91.28% |
| Multi Family | 350 | 2.73% |
| Commercial | 638 | 4.98% |
| Other* | 64 | 0.50% |
| Inactive connections | 66 | 0.52% |
| Total: | 12,815 | 100.00% |

*Fire suppression, street cleaning, line flushing, construction meters and temporary meters.



**INDIAN WELLS VALLEY WATER DISTRICT
DOMESTIC WATER SYSTEM
PROJECTED WATER PRODUCTION REQUIREMENTS
AND SERVICE CONNECTIONS**

| YEAR | PROJECTED WATER PRODUCTION REQUIREMENTS (AF) | PROJECTED SERVICE CONNECTIONS (EA) |
|-------------|---|---|
| 2018 | 6,765 ⁽¹⁾ | 12,749 ⁽¹⁾ |
| 2020 | 6,730 | 12,602 |
| 2025 | 6,930 | 12,976 |
| 2030 | 7,130 | 13,347 |
| 2035 | 7,690 | 14,399 |
| 2040 | 7,830 | 14,671 |
| 2045 | 8,050 | 15,079 |

(1) Actual



DEMAND DISTRIBUTION

- ▶ Existing demands were set up using meter routes, distributed to system nodes
- ▶ Future demands were distributed using estimated ultimate population projections (2045) from KernCOG for Transportation Analysis Zones (TAZs) within District Service Area. Growth was distributed to nodes within each TAZ.

AVERAGE AND MAXIMUM DAY DEMANDS

- ▶ Factors used for sizing facilities
- ▶ Average Day Demand (ADD)
 - Current: 6.0 MGD
 - Ultimate: 7.2 MGD
- ▶ Maximum Day Demand (MDD) = 2.0 X ADD
 - Current: 12.0 MGD
 - Ultimate: 14.4 MGD

RESERVOIR STORAGE COMPONENTS

- ▶ Operational Storage (to even out the daily demands and provide adequate system pressure) = $0.2 \times \text{MDD}$
- ▶ Emergency Storage (to provide additional storage in the case of a temporary power or service outage)
 - Minimum = $1.0 \times \text{ADD}$ (24 hours of ADD)
 - Optimum = $1.0 \times \text{MDD}$ (24 hours of MDD)
- ▶ Off-Peak Power (OPP) Storage = $5 \text{ hrs}/24 \text{ hrs} (0.21) \times \text{MDD}$
- ▶ Fire Flow Storage varies by pressure zone

FIRE FLOW REQUIREMENTS BY PRESSURE ZONE

| Zone Designation | | Fire Flow (gpm) | Duration (hours) | Storage Requirements (gallons) |
|------------------|------|-----------------|------------------|--------------------------------|
| Elevation | Name | | | |
| 2,455 | A | 4,000 | 4 | 960,000 |
| 2,555 | B | 2,000 | 4 | 480,000 |
| 2,660 | C | 2,000 | 2 | 240,000 |
| 2,775 | D | 1,500 | 2 | 180,000 |
| 2,885 | E | 3,000 | 3 | 540,000 |

**PROJECTED PRODUCTION REQUIREMENTS BY PRESSURE ZONE IN GALLONS PER MINUTE
(NORMAL OPERATION)**

| Pressure Zone | Production Demand | 2018 | 2025 | 2030 | 2035 | 2040 | 2045 | Existing |
|---------------------|--------------------|--------------|--------------|--------------|--------------|--------------|--------------|------------------------------|
| A Zone (2455) | Average Day | 3,112 | 3,217 | 3,343 | 3,471 | 3,680 | 3,893 | 8,500 |
| | Maximum Day | 6,225 | 6,434 | 6,686 | 6,942 | 7,361 | 7,786 | |
| B Zone (2555) | Average Day | 739 | 742 | 744 | 745 | 746 | 749 | 4,400 ⁽²⁾ |
| | Maximum Day | 1,478 | 1,483 | 1,487 | 1,490 | 1,492 | 1,498 | |
| C Zone (2660) | Average Day | 201 | 201 | 201 | 201 | 201 | 201 | (2) |
| | Maximum Day | 402 | 402 | 402 | 402 | 402 | 402 | |
| D Zone (2775) | Average Day | 43 | 43 | 43 | 43 | 43 | 43 | (2) |
| | Maximum Day | 86 | 86 | 86 | 86 | 86 | 86 | |
| E Zone (2885) | Average Day | 99 | 99 | 99 | 99 | 99 | 99 | (2) |
| | Maximum Day | 198 | 198 | 198 | 198 | 198 | 198 | |
| SYSTEM TOTAL | Average Day | 4,194 | 4,301 | 4,429 | 4,559 | 4,769 | 4,985 | 12,900 ⁽³⁾ |
| | Maximum Day | 8,388 | 8,603 | 8,859 | 9,118 | 9,538 | 9,969 | |

Notes:

- (1) Not including Well 35.
- (2) B Zone production supplies C, D and E Zones
- (3) Not accounting for any necessary future well replacements.

**PROJECTED PRODUCTION REQUIREMENTS BY PRESSURE ZONE IN GALLONS PER MINUTE
(OFF PEAK POWER) ⁽⁴⁾**

| Pressure Zone | Production Demand | 2018 | 2025 | 2030 | 2035 | 2040 | 2045 | Existing Production ⁽¹⁾ |
|---------------------|--------------------|---------------|---------------|---------------|---------------|---------------|---------------|------------------------------------|
| A Zone (2455) | Average Day | 3,931 | 4,064 | 4,223 | 4,385 | 4,649 | 4,917 | 8,500 ⁽³⁾ |
| | Maximum Day | 7,863 | 8,127 | 8,446 | 8,769 | 9,297 | 9,835 | |
| B Zone (2555) | Average Day | 934 | 937 | 939 | 941 | 943 | 946 | 4,400 ⁽²⁾ |
| | Maximum Day | 1,867 | 1,874 | 1,879 | 1,882 | 1,885 | 1,893 | |
| C Zone (2660) | Average Day | 254 | 254 | 254 | 254 | 254 | 254 | (2) |
| | Maximum Day | 507 | 507 | 507 | 507 | 507 | 507 | |
| D Zone (2775) | Average Day | 54 | 54 | 54 | 54 | 54 | 54 | (2) |
| | Maximum Day | 109 | 109 | 109 | 109 | 109 | 109 | |
| E Zone (2885) | Average Day | 125 | 125 | 125 | 125 | 125 | 125 | (2) |
| | Maximum Day | 250 | 250 | 250 | 250 | 250 | 250 | |
| SYSTEM TOTAL | Average Day | 5,298 | 5,433 | 5,595 | 5,759 | 6,024 | 6,296 | 12,900 ⁽⁵⁾ |
| | Maximum Day | 10,595 | 10,867 | 11,190 | 11,517 | 12,048 | 12,593 | |

Notes:

- (1) Not including Wells 35 and 36.
- (2) B Zone production supplies C, D and E Zones
- (3) B Zone production supplements A Zone demand requirements.
- (4) Requires Maximum Day Production over a 19 hour period (no production between 4:00 pm and 9:00 pm).
- (5) Not accounting for any necessary future well replacements.



WATER SUPPLY

- ▶ Existing Sources of Water Supply
 - Groundwater
- ▶ Potential Sources of Future Water Supply
 - Groundwater (including brackish groundwater)
 - Importation of Surface Water – Groundwater Replenishment
 - Recycled Water (City of Ridgecrest) – Groundwater Replenishment
- ▶ Groundwater Management
 - GSA: minimum 5,000 AF/Yr must be imported, to be financed by IWVWD and SVM.




EXISTING SYSTEM

- ▶ System Schematic
- ▶ System Map
- ▶ Potential Annexations
- ▶ System Model
- ▶ System Issues
- ▶ Proposed Resolution of System Issues




178-148_map1.dwg



KRIEGER & STEWART
 Engineering Consultants
 3602 University Avenue • Riverside, CA 92501
 www.kriegerandstewart.com • 951-684-6900





EXISTING FACILITIES LEGEND

- | | | |
|--------------------------------|------------------------------|--------|
| 6" AND BELOW EXISTING PIPELINE | ZONE-BREAK CONTOUR - 2350 FT | A ZONE |
| 8" EXISTING PIPELINE | ZONE-BREAK CONTOUR - 2450 FT | B ZONE |
| 10" EXISTING PIPELINE | ZONE-BREAK CONTOUR - 2550 FT | C ZONE |
| 12" EXISTING PIPELINE | ZONE-BREAK CONTOUR - 2650 FT | D ZONE |
| 14" EXISTING PIPELINE | INWVD BOUNDARY | E ZONE |
| 16" EXISTING PIPELINE | EXISTING STORAGE RESERVOIR | |
| 24" EXISTING PIPELINE | EXISTING WELL | |
| 30" EXISTING PIPELINE | | |

VERIFY SCALES
 BAR IS ONE INCH ON ORIGINAL DRAWING
 0 1" 1"
 IF NOT ONE INCH ON THIS SHEET, ADJUST SCALES ACCORDINGLY

KRIEGER & STEWART
 Engineering Consultants
 3403 University Avenue • Riverside, CA 92501
 www.kriegersandstewart.com • 951-684-8900

SCALE: 1"=2000' DATE: 12/07/20 DRAWN BY: SPK CHECKED BY: NEW W.O.: 178-148

INDIAN WELLS VALLEY WATER DISTRICT
 2020 WATER GENERAL PLAN UPDATE
EXISTING FACILITIES

FIGURE
1
 OF 3



EXISTING SYSTEM: Potential Annexations

- ▶ The State Water Resources Control Board, Division of Drinking Water, has requested that the District consider annexing several small water systems:
- ▶ Small Systems in the China Lake Area (covered by KernCOG population estimates—connections not included)
 - Dune III Mutual Water Company (population 119, 36 residential connections)
 - China Lake Acres Mutual Water Company (population 198, 60 residential connections)
 - Buttermilk Acres Water System (2 commercial connections)
 - Hometown Water Association (population 25, 12 residential connections)
 - Sierra Breeze Mutual Water Company (population 150, 60 residential connections)




EXISTING SYSTEM: Potential Annexations (continued)

- ▶ Inyokern Area (not included)
 - Inyokern CSD (ICSD) (population 1002, 244 residential connections, 20 commercial connections, 1 irrigation connection)
 - East Inyokern Mutual Water Company (population 87, 28 residential connections)
 - Gateway Market Water System (2 commercial connections)


- ▶ South Inyokern Area (not included)
 - Life Water Co-op (population 27, 18 residential connections)
 - Owens Peak West (population 60, 24 residential connections)
 - 148 East Water System (population 35, 13 residential connections)
 - South Desert Mutual Water Company (population 26, 13 residential connections)
 - Owens Peak South (population 40, 17 residential connections)

- ▶ North Inyokern Area (not included)
 - West Valley Mutual Water Company (population 70, 41 residential connections)
 - Sweet Water Co-op (population 47, 15 residential connections)





EXISTING SYSTEM: System Model (Street Map Background)



EXISTING SYSTEM: System Model (Aerial Photo Background)

147-148_Model.mxd - ArcMap

File Edit View Bookmarks Insert Selection Geoprocessing Customize Windows Help

1:15,000

InfoWater

Table Of Contents

- Layers
 - Junction
 - Tank
 - Reservoir
 - Pump
 - Valve
 - Pipe
 - CNTR_1
 - to be removed
 - Questions
 - Network GIS
 - Streets
 - IWWWD Annexations
 - service_area
 - PressureZone
 - Annotation
 - Meter Routes
 - Parcel
 - Kern_TAZ
 - Basemap
 - World Street Map
 - Aerial_2014_Kern_1ft_
 - USA Topo Maps
 - World Topographic M
 - Citations
 - World Imagery
 - USGS_13_n36w118.tif

Model Explorer

ULT_MDD_OPP

Active:Standard Refresh Output

00:00 hrs

PIPE: P2314, Existing Pipe

| (ID) | Description |
|-------|---------------|
| P2314 | Existing Pipe |

| Property | Value |
|----------------------|---------|
| Geometry | Reverse |
| Start Node | J2052 |
| End Node | J2054 |
| Modeling | |
| Length (ft) | 476.13 |
| Diameter (in) | 6.00 |
| Roughness | 130.00 |
| Minor Loss | 0.00 |
| Totalizer | No |
| Check Valve | No |
| Information | |
| Year of Installation | 1988 |
| Year of Retirement | |
| Zone | C |
| Material | APC |
| Lining | |
| Cost ID | |
| Phase | |

Message Board

Message Validation Result

6647275.684 2404046.557 Feet

EXISTING SYSTEM: System Model (USGS Topo Background)

147-148_Model.mxd - ArcMap

File Edit View Bookmarks Insert Selection Geoprocessing Customize Windows Help

1:15,000

InfoWater

Table Of Contents

Layers

- Junction
- Tank
- Reservoir
- Pump
- Valve
- Pipe
- CNTR_1
- to be removed
- Questions
- Network GIS
- Streets
- IWWWD Annexations
- service_area
- PressureZone
- Annotation
- Meter Routes
- Parcel
- Kern_TAZ
- Basemap
 - World Street Map
 - Aerial_2014_Kern_1ft_
 - USA Topo Maps
 - World Topographic V
 - Citations
 - World Imagery
 - USGS_13_n36w118.tif

Message Board

Message Validation Result

Model Explorer

ULT_MDD_OPP

Active Standard Refresh Output

00:00 hrs

PIPE: P2314, Existing Pipe

| (ID) | Description | Reverse |
|---|---------------|---------|
| P2314 | Existing Pipe | Reverse |
| <input checked="" type="checkbox"/> Geometry | | |
| Start Node | J2052 | |
| End Node | J2054 | |
| <input checked="" type="checkbox"/> Modeling | | |
| Length (ft) | 476.13 | |
| Diameter (in) | 6.00 | |
| Roughness | 130.00 | |
| Minor Loss | 0.00 | |
| Totalizer | No | |
| Check Valve | No | |
| <input checked="" type="checkbox"/> Information | | |
| Year of Installation | 1988 | |
| Year of Retirement | | |
| Zone | C | |
| Material | APC | |
| Lining | | |
| Cost ID | | |
| Phase | | |
| Output | | |

6650843.392 2403083.016 Feet

System Issues

- ▶ Maintaining consistent reservoir levels without impacting fire-flow and emergency storage
- ▶ High-pressure area in Zone B when Ridgecrest Heights and Springer Reservoirs are full, and Gateway Reservoir is filling. High pressures are sufficient to cause pipe failures.
- ▶ Summary: Undersized East-West and North-South Arteries
- ▶ These problems will increase in severity under future conditions without system improvements.

System Issues: Proposed Resolution


▶ A-Zone Improvements

- Construction of A-4 Reservoir
- Construction of 30" Pipeline in Bowman Rd. from Brady St. to China Lake Blvd.
- Construction of 24" Pipeline (30" for OPP – nominal cost difference) in Bowman Road from China Lake Blvd. to Proposed A-4 Reservoir
- (For OPP only) Construction of 30" Pipeline in College Heights Blvd. from Bowman Rd. to Kendal Reservoir
- (For OPP only) Utilization of Springer PRV

▶ B-Zone Improvements

- Construction of 24" Pipeline in Springer Ave. from Mahan St. to College Heights Blvd.
- Construction of 24" Pipeline in Gateway Blvd. from Springer Ave. to Gateway Reservoirs





EXISTING FACILITIES LEGEND

- | | | |
|--------------------------------|------------------------------|--------|
| 6" AND BELOW EXISTING PIPELINE | ZONE-BREAK CONTOUR - 2350 FT | A ZONE |
| 8" EXISTING PIPELINE | ZONE-BREAK CONTOUR - 2450 FT | B ZONE |
| 10" EXISTING PIPELINE | ZONE-BREAK CONTOUR - 2550 FT | C ZONE |
| 12" EXISTING PIPELINE | ZONE-BREAK CONTOUR - 2650 FT | D ZONE |
| 14" EXISTING PIPELINE | INWVD BOUNDARY | E ZONE |
| 16" EXISTING PIPELINE | EXISTING STORAGE RESERVOIR | |
| 24" EXISTING PIPELINE | EXISTING WELL | |
| 30" EXISTING PIPELINE | | |

VERIFY SCALES
 BAR IS ONE INCH ON ORIGINAL DRAWING
 0 1" IF NOT ONE INCH ON THIS SHEET, ADJUST SCALES ACCORDINGLY



INDIAN WELLS VALLEY WATER DISTRICT


2020 WATER GENERAL PLAN UPDATE
 PROPOSED FACILITIES
 NORMAL OPERATION

FIGURE

2



A Zone Tanks With Existing Demand (Normal Operation)




*Not including proposed A-4 tank

- (1) 24" pipeline in Bowman Rd from Brady St to China Lake Blvd.
- (2) As above and 30" pipeline in Bowman Rd from China Lake Blvd to A-4 Tank

- Kendal (Existing)
- Bowman (Existing)
- Supply (Existing)
- - - Kendal (1)
- - - Bowman (1)
- - - Supply (1)
- · · A-4 Tank (2)
- · · Bowman (2)
- · · Supply (2)



A Zone Tanks With Ultimate Demand (Normal Operation)



*Not including proposed A-4 tank

- (1) 24" pipeline in Bowman Rd from Brady St to China Lake Blvd.
- (2) As above and 30" pipeline in Bowman Rd from China Lake Blvd to A-4 Tank


- Kendal (Existing)
- Bowman (Existing)
- A-4 Tank (2)
- Supply (2)
- Kendal (1)
- Bowman (1)
- Supply (Existing)
- Kendal (2)
- Bowman (2)
- Supply (1)



System Issues (Continued): B-Zone High-Pressure Area



B Zone Tanks With Existing Demand (Normal Operation)




*Not including proposed 1.0MG Gateway Tank
 Note: High pressure located near the intersection of Upjohn Ave and Downs St

(1) 24" in Springer Ave from Mahan St to College Heights Blvd
 (2) As above and 24" in Gateway from Springer Ave to Gateway Tank

- Gateway (Existing)
- Gateway (1)
- Gateway (2)
- R/C Heights (Existing)
- R/C Heights (1)
- R/C Heights (2)
- Springer (Existing)
- Springer (1)
- Springer (2)
- High Pressure (Existing)
- High Pressure (1)
- High Pressure (2)




B Zone Tanks With Ultimate Demand (Normal Operation)



| | | | | |
|---|---|-----------------------------------|----------------------------|----------------------------|
| <p>*Not including proposed 1.0MG Gateway Tank</p> <p>Note: High pressure located near the intersection of Upjohn Ave and Downs St</p> | <p>(1) 24" in Springer Ave from Mahan St to College Heights Blvd</p> <p>(2) As above and 24" in Gateway from Springer Ave to Gateway Tank</p> | <p>— Gateway (Existing)</p> | <p>— Gateway (1)</p> | <p>• Gateway (2)</p> |
| | | <p>— R/C Heights (Existing)</p> | <p>— R/C Heights (1)</p> | <p>• R/C Heights (2)</p> |
| | | <p>— Springer (Existing)</p> | <p>— Springer (1)</p> | <p>• Springer (2)</p> |
| | | <p>— High Pressure (Existing)</p> | <p>— High Pressure (1)</p> | <p>• High Pressure (2)</p> |





EXISTING FACILITIES LEGEND

| | | |
|--------------------------------|------------------------------|--------|
| 6" AND BELOW EXISTING PIPELINE | ZONE-BREAK CONTOUR - 2350 FT | A ZONE |
| 8" EXISTING PIPELINE | ZONE-BREAK CONTOUR - 2450 FT | B ZONE |
| 10" EXISTING PIPELINE | ZONE-BREAK CONTOUR - 2550 FT | C ZONE |
| 12" EXISTING PIPELINE | ZONE-BREAK CONTOUR - 2650 FT | D ZONE |
| 14" EXISTING PIPELINE | INVID BOUNDARY | E ZONE |
| 16" EXISTING PIPELINE | EXISTING STORAGE RESERVOIR | |
| 18" EXISTING PIPELINE | EXISTING WELL | |
| 24" EXISTING PIPELINE | | |
| 30" EXISTING PIPELINE | | |

VERIFY SCALES
BAR IS ONE INCH ON
ORIGINAL DRAWING

IF NOT ONE INCH ON
THIS SHEET, ADJUST
SCALES ACCORDINGLY

KRIEGER & STEWART
Engineering Consultants
3402 University Avenue • Riverside, CA 92501
www.kriegersandstewart.com • 951-684-6900

SCALE: 1"=2000'

INDIAN WELLS VALLEY WATER DISTRICT
2020 WATER GENERAL PLAN UPDATE
PROPOSED FACILITIES
OFF PEAK POWER


DATE: 12/07/20
DRAWN BY: SPK
CHECKED BY: NRM
W.O.: 178-148

FIGURE
3
OF 3



DWG. NO.: 178-148-03, FILE NO.: 178-148, UPDATE BY: SPK, PROJ. DWG. NO.: 178-148, PLOT TIME: 11:20AM, PLOT SCALE: 1"=1"

A Zone Tanks With Existing Demand (Off Peak Power)



*Including future A-4 Tank (5.0 MG)


Note: All B Zone improvements assumed to be constructed, and Springer PRV is active.

- (1) 30" pipeline in Bowman Rd from China Lake Blvd to A-4 Tank.
- (2) As above and 30" pipeline in Bowman Rd from Brady St to China Lake Blvd.
- (3) As above and 30" pipeline in College Heights Blvd from Bowman Rd to Kendal Tank.

- | | | |
|--------------|--------------|----------------|
| — Kendal (1) | — Kendal (2) | • Kendal (3) |
| — Bowman (1) | — Bowman (2) | • Bowman (3) |
| — A-4 (1) | — A-4 (2) | • A-4 Tank (3) |
| — Supply (1) | — Supply (2) | • Supply (3) |



A Zone Tanks With Ultimate Demand (Off Peak Power)



*Including future A-4 Tank (5.0 MG)


Note: All B Zone improvements assumed to be constructed and Springer PRV is active.

- (1) 30" pipeline in Bowman Rd from China Lake Blvd to A-4 Tank.
- (2) As above and 30" pipeline in Bowman Rd from Brady St to China Lake Blvd.
- (3) As above and 30" pipeline in College Heights Blvd from Bowman Rd to Kendal Tank.

- Kendal (1)
- Kendal (2)
- Kendal (3)
- Bowman (1)
- Bowman (2)
- Bowman (3)
- A-4 (1)
- A-4 (2)
- A-4 Tank (3)
- Supply (1)
- Supply (2)
- Supply (3)



B Zone Tanks With Existing Demand (Off Peak Power)




*Not including proposed 1.0MG Gateway Tank
 Note: High pressure located near the intersection of Upjohn Ave and Downs St

(1) 24" in Springer Ave from Mahan St to College Heights Blvd
 (2) As above and 24" in Gateway from Springer Ave to Gateway Tank

- Gateway (Existing) - - Gateway (1) - . Gateway (2)
- R/C Heights (Existing) - - R/C Heights (1) - . R/C Heights (2)
- Springer (Existing) - - Springer (1) - . Springer (2)
- High Pressure (Existing) - - High Pressure (1) - . High Pressure (2)



B Zone Tanks With Ultimate Demand (Off Peak Power)



*Not including proposed 1.0MG Gateway Tank
 Note: High pressure located near the intersection of Upjohn Ave and Downs St

(1) 24" in Springer Ave from Mahan St to College Heights Blvd
 (2) As above and 24" in Gateway from Springer Ave to Gateway Tank

- Gateway (Existing) - - Gateway (1) ··· Gateway (2)
- R/C Heights (Existing) - - R/C Heights (1) ··· R/C Heights (2)
- Springer (Existing) - - Springer (1) ··· Springer (2)
- High Pressure (Existing) - - High Pressure (1) ··· High Pressure (2)



DISASTER PREPAREDNESS

- ▶ A disaster preparedness project, currently in the design phase, will replace damaged facilities and increase storage at four reservoir sites.
- ▶ Project will mitigate impacts of future power outages and earthquakes, will provide reserve storage for repair and maintenance activities, and may be used to provide supplemental storage for other zones.
- ▶ The project will add redundant storage capacity in B, C, and E Zones in excess of General Plan criteria:
 - **B Zone:** 1.0 MG new capacity (Gateway Reservoir)
 - **C Zone:** 0.6 MG net increase in capacity
 - **E Zone:** 0.55 MG new capacity (College Reservoir)

ULTIMATE STORAGE FACILITY REQUIREMENTS BY PRESSURE ZONE
IN MILLION GALLONS (MG)
COMPARED TO EXISTING STORAGE PLUS DISASTER PREPAREDNESS PROJECT

| Zone | Storage Component | Required Storage | | | | Existing Storage | Existing Storage With Disaster Preparedness |
|-------------------------|-------------------|------------------|--------------------|--------------|--------------------|------------------|---|
| | | Minimum | Minimum + Off-Peak | Optimum | Optimum + Off-Peak | | |
| A-Zone (2455) | Operational | 2.24 | 2.24 | 2.24 | 2.24 | 9.00 | 9.00 |
| | Fire | 0.96 | 0.96 | 0.96 | 0.96 | | |
| | OPP | 0.00 | 2.34 | 0.00 | 2.34 | | |
| | Emergency | 5.61 | 5.61 | 11.21 | 11.21 | | |
| | Total | 8.81 | 11.14 | 14.41 | 16.75 | | |
| B-Zone (2555) | Operational | 0.43 | 0.43 | 0.43 | 0.43 | 5.55 | 6.55 |
| | Fire | 0.48 | 0.48 | 0.48 | 0.48 | | |
| | OPP | 0.00 | 0.45 | 0.00 | 0.45 | | |
| | Emergency | 1.08 | 1.08 | 2.16 | 2.16 | | |
| | Total | 1.99 | 2.44 | 3.07 | 3.52 | | |
| C-Zone (2660) | Operational | 0.12 | 0.12 | 0.12 | 0.12 | 1.40 | 2.00 |
| | Fire | 0.24 | 0.24 | 0.24 | 0.24 | | |
| | OPP | 0.00 | 0.12 | 0.00 | 0.12 | | |
| | Emergency | 0.29 | 0.29 | 0.58 | 0.58 | | |
| | Total | 0.64 | 0.77 | 0.93 | 1.05 | | |
| D-Zone (2775) | Operational | 0.02 | 0.02 | 0.02 | 0.02 | 0.50 | 0.50 |
| | Fire | 0.18 | 0.18 | 0.18 | 0.18 | | |
| | OPP | 0.00 | 0.03 | 0.00 | 0.03 | | |
| | Emergency | 0.06 | 0.06 | 0.12 | 0.12 | | |
| | Total | 0.27 | 0.29 | 0.33 | 0.35 | | |
| E-Zone (2885) | Operational | 0.06 | 0.06 | 0.06 | 0.06 | 0.55 | 1.10 |
| | Fire | 0.54 | 0.54 | 0.54 | 0.54 | | |
| | OPP | 0.00 | 0.06 | 0.00 | 0.06 | | |
| | Emergency | 0.14 | 0.14 | 0.28 | 0.28 | | |
| | Total | 0.74 | 0.80 | 0.88 | 0.94 | | |
| Totals | Operational | 2.87 | 2.87 | 2.87 | 2.87 | 17.00 | 19.15 |
| | Fire | 2.40 | 2.40 | 2.40 | 2.40 | | |
| | OPP | 0.00 | 2.99 | 0.00 | 2.99 | | |
| | Emergency | 7.18 | 7.18 | 14.36 | 14.36 | | |
| | TOTAL | 12.45 | 15.44 | 19.63 | 22.62 | | |



DISASTER PREPAREDNESS: SUMMARY

- ▶ Zones B,C,D, and E will increase supplemental storage with implementation of Disaster Preparedness project.
- ▶ A-Zone, even with the addition of Reservoir A-4, will not have sufficient storage on its own to satisfy ultimate storage requirements with optimum emergency storage; but it would be possible to make use of B-Zone's excess storage in A-Zone.
- ▶ Consider policy question of whether Disaster Preparedness storage should be reserved exclusively for disaster preparedness, or used for other purposes such as Off-Peak Power storage in A-Zone.



Questions?



PRESENTED BY:

Krieger & Stewart, Incorporated
(951) 684-6900

Charles A. Krieger
ckrieger@kriegerandstewart.com